

**LadyBug Technologies LLC**  
**Manual PowerSensor+ Field Certification Procedure**

**Procedure Applies to Following Power Sensors**

**LB478A, LB479A, LB480A, LB559A, LB579A, LB589A, LB679A, LB680A**

## Contents

Purpose: .....	3
Products Covered by Procedure: .....	3
Overview: .....	3
Required Equipment: .....	4
Test Procedure: .....	7
1. Select the TR (Test Record) .....	7
2. Physical and functional check of UUT .....	8
3. Warm up .....	9
4. Match .....	<b>Error! Bookmark not defined.</b>
5. Absolute Level Accuracy .....	9
6. Linearity .....	13
Test Record for LB478A, LB479A .....	15
Test Record for LB480A .....	16
Test Record for LB559A .....	17
Test Record for LB579A .....	18
Test Record for LB589A .....	19
Test Record for LB679A, LB680A, N-Type Connector .....	20
Test Record for LB679A, LB680A, SMA Connector .....	21

**Purpose:**

This documents the certification process for LadyBug Technologies LLC (LadyBug) PowerSensor+ line of products. This procedure is a manual procedure and is intended to satisfy the needs of traceable annual recertification. In addition, this procedure is useful for recertifying sensors whose connectors have been replaced with connectors of an identical type (e.g. N-Type male with N-Type male or N-Type male with N-Type female).

This procedure certifies that the existing calibration factors associated with the unit-under-test (UUT) and used properly allows the UUT to make accurate measurements within the procedure's specified uncertainty limits. Since calibration factors for Ladybug sensors include temperature corrections factors and this procedure only measures the UUT at ambient temperature, new calibration factors are NOT generated. Any sensors failing this procedure, or if a sensor's connector is type is changed (e.g. changed from Type-N to SMA) the sensor must be returned to the factory for repair and/or adjustment.

**Products Covered by Procedure:**

This procedure applies to the following LadyBug PowerSensor+ products listed below:

LB478A, LB479A, LB480A, LB559A, LB579A, LB589A, LB679A, LB680A

**Overview:**

This procedure applies to sensors that are in good working order, fully functional and without mechanical defect or damage. If there is any question about the serviceability or functionality of the sensor, consult the "User's Manual" to ascertain the state of the sensor or contact LadyBug Technologies LLC for advice. This certification procedure consists of six steps:

1. Configure/setup of the certification test system
2. Select the Test Record
3. Physical and functional check of UUT
4. Warm up
5. Absolute level accuracy Test
6. Linearity Test

As with any procedure, it is impractical to verify all conditions and states. This procedure tests a selected set of measurement points. These points are sufficient to ensure a high level of confidence in the sensor's continued performance. As with all calibration procedures, there is great reliance on the experience, knowledge, sound judgment and skill of those doing the work.

Finally, if, during the calibration process, the sensor fails at any point, follow local procedures for recording and resolving the problem before proceeding.

Certification traceability to national standards is accomplished through a locally calibrated SOURCE and factory calibrated CAL\_SENSOR and REF\_SENSOR.

## Required Equipment:

This section lists the equipment required for the certification procedure. This procedure refers to equipment by "Name" rather than model number. For example, rather than refer to an "HP 8340B" (see Table 1) the calibration procedure refers to "SOURCE". This term, "SOURCE", comes from the **Required Equipment** table **Procedure Name** column. In addition, the uncertainties used within the procedure to certify the UUT are based on using "REF\_SENSOR" and "CAL\_SENSOR" power meters from LadyBug Technologies.

Necessary Equipment (refer to Table 1 for recommended models):

- 1) **SOURCE**: a stable and repeatable signal generator with sufficient frequency and power range (and resolution) to test the UUT (Unit Under Test) or multiple UUT's;
- 2) **SPLITTER**: a 2-resistor uW power splitter that is specified over the necessary frequency range of the UUT's to be tested. It is recommended that a quality, broadband power splitter that operates from 10 MHz to 26.5 GHz be used;
- 3) **CAL\_SENSOR**: a factory calibrated Ladybug USB power sensor that has the same connector type and sex that is present on the UUT. If there are multiple UUT's with different RF connector types and sex, multiple CAL\_SENSOR's will be needed;
- 4) **REF\_SENSOR**: a factory calibrated Ladybug USB sensor that is used in the test to ensure that the same power level (at each frequency) is delivered to both the CAL\_SENSOR and UUT ;
- 5) **CAL\_ADAPT**: an RF adapter that presents the same RF connector interface between both the UUT\_SENSOR and the CAL\_SENSOR and the broadband SPLITTER. This approach minimizes mismatch error within the test. If the UUT\_SENSOR and CAL\_SENSOR RF connector directly connect to the SPLITTER without the use of any adapter, then a CAL\_ADAPT is not required.
- 6) A computer running Windows XP or Windows 7: required to operate the LB Power Meter Application for each sensor connected (REF\_SENSOR, CAL\_SENSOR, UUT\_SENSOR).
- 7) A USB 2.0 powered hub may be needed to ensure that all of the sensors can be powered and operated at the same time: ensure that the hub can deliver 500 mA of current at each of its ports at the same time.
- 8) High quality cables and precision adapters to connect the SPLITTER to the SOURCE and to the REF\_SENSOR and UUT\_SENSOR/CAL\_SENSOR. This hardware is not called out in the equipment list.

This procedure applies to several sensors and connectors. Understandably, the equipment requirements vary. However, some of the equipment applies to all sensors. Other equipment varies by the UUT model number and UUT connector type and UUT connector sex. Pay special attention to the type of UUT you are certifying when selecting your equipment.

If you choose to substitute equipment consult the equipment list for information. Also, be aware of the test range for each sensor. These test ranges for each sensor are shown below:

- LB478A: 10 MHz – 8 GHz
- LB479A: 10 MHz – 8 GHz
- LB480A: 50 MHz – 8 GHz (100 MHz – 8 GHz for LB480A serial numbers <117xxx)
- LB559A: 10 MHz – 12.5 GHz
- LB579A: 10 MHz – 18 GHz
- LB589A: 10 MHz – 26.5 GHz
- LB679A: 50 MHz – 18 GHz
- LB680A: 50 MHz – 18 GHz

When selecting your equipment be sure to check the equipment for damage or excessive wear. SWR or match is the single biggest contributor to error and uncertainty in power measurements. So, using worn or damaged connectors during calibration can induce “false failures”.

This same advice applies when selecting cables. Use high quality cables during calibration. And ensure they are in good working order. Also, when building the setups, keep cables as short as possible and keep the strain on the cables at a minimum.

Finally, if you choose to substitute any of the passive devices (adapters, attenuators or splitters) pay close attention to specified SWR or match. It is recommended that the SPLITTER and CAL\_ADAPT components be of high quality.


Keep in mind that SWR or port mismatch is the single biggest contributor to error and uncertainty (mismatch at the input to the sensor). As such, selecting components with marginal performance will degrade the quality of the measurements and can easily induce “false failures” during calibration.

Procedure Name	UUT Connector		Equipment Model Number	Comments
	Sex	Type		
UUT	ALL	ALL	<u>U</u> n <u>i</u> t <u>U</u> nder <u>T</u> est	The sensor you wish to calibrate
TR	ALL	ALL	<u>T</u> est <u>R</u> ecord	The test record is selected in step 1
PC	ALL	ALL	PC running Windows XP, Service Pack 3 or Windows 7 and up to date	Keyboard, mouse etc as required
PM_APP	ALL	ALL	Power meter application. Software available for download from: <a href="http://www.ladybug-tech.com/">http://www.ladybug-tech.com/</a>	Power Meter application is part of standard application installation.
SOURCE/Signal Generator	ALL	ALL	Agilent N5183A or equivalent with adaptaters and cable necessary to connect to the SPLITTER 3.5 mm female RF input.	Suitable substitutes with equal to or better: Harmonics Power level (-100 dBm to +20 dBm) Frequency range and programmable
SPLITTER	F	SMA/3.5 mm	Agilent 11667B , 2 resistor splitter, 26.5 GHz or equivalent	The SPLITTER and CAL_ADAPT in UUT connector
USB Hub			Powered USB 2.0 Hub	USB 2.0 and capable of delivering 500 mA at each USB port
REF_SENSOR	M	SMA	LB589A Opt OSM	Recommended Factory calibrated sensors
CAL_SENSOR	M	N-Type	LB579A Opt ONM	Factory calibrated sensors
	F	N-Type	LB579A Opt ONF	
	M	SMA	LB589A Opt OSM	
	F	SMA	LB589A Opt OSF	
CAL_ADAPT	M	N-Type	N female to SMA male or N female to 3.5 mm male	If configuring your own splitter with SMA female or 3.5 mm female connectors, and your own CAL_ADAPT, select the cal sensor adapter based on the UUT connector type and UUT connector sex always to 3.5 mm male (for example: N-female to 3.5 mm male for UUT connector type of Type N male)
	F	N-Type	N male to SMA male or N male to 3.5 mm male	
	M	SMA	No adapter necessary, but if you choose one it must be either a SMA female to SMA male or 3.5 mm female to 3.5 mm male	
	F	SMA	SMA male to SMA male or 3.5 mm male to 3.5 mm male	

**Table 1: Required Equipment**

## Test Procedure:

### 1. Configure the test system



**Configuration Diagram for Field Certification procedure**

Use high quality cables and adapters when making all RF connections.

## 2. Select the TR (Test Record)

Determine the UUT model number, RF connector type and RF connector sex. Select the TR (or test record) at the end of this document that applies to the UUT you have chosen to certify. Copy or print the test record. Record the following on the TR:

- a. *Enter Date on TR*
- b. *Enter UUT model number on TR*
- c. *Enter UUT serial number (rear of UUT, below USB connection) on TR*
- d. *Enter UUT connector type on TR*
- e. *Enter UUT connector sex on TR*
- f. *Enter UUT last calibration date on TR*

### Physical and functional check of UUT

- g. Inspect the UUT for signs of physical and/or mechanical damage. Enter result on TR.
- h. Inspect the UUT connector for signs of wear or damage. *Enter result on TR.*
- i. Connect the UUT to the PC.
- j. Turn on and preset the SOURCE.
- k. Set SOURCE power to off.
- l. Connect SOURCE to UUT RF input connector (use adapters as required).
- m. Start the PM\_APP.
- n. After the PM\_APP starts, click PM\_APP Reset button. The PM\_APP switch to CW mode.
- o. By exercising the UUT over power and frequency, satisfy yourself that the UUT is functioning properly. Use the outline below.
  - i. Set SOURCE power off
  - ii. Set SOURCE frequency
  - iii. Set the UUT frequency (using the PM\_APP)
  - iv. Set SOURCE power to less than +20 dBm.
  - v. Set SOURCE power on
  - vi. Read UUT power.
  - vii. As you vary SOURCE power, make readings on the UUT.
  - viii. With a high quality SOURCE, UUT power readings should agree within about +-1 dB. You may see larger disagreement with some sources.
  - ix. Exercise the UUT over its entire power range.
- p. *Enter result of the Functional Test on TR.*




### 3. Warm up

- a. For 24 hours prior to and during execution of this test procedure the UUT must be in a stable laboratory environment. In addition, the sensor should be powered for at least 1 hour before starting the test. Stable environmental conditions are defined as:
  - Temperature: 20° C to 30° C (68°F to 86°F)
  - Humidity: 15% to 95% non-condensing
  - Altitude: Sea Level to 3,000 meters (10,000 feet)
- b. All equipment requiring power should be connected to mains and warmed up per manufacturers recommendations.
- c. *Enter temperature on TR.*
- d. *Enter humidity on TR.*

### 4. Absolute Level Accuracy

- a. Connect the SOURCE, SPLITTER, PC, REF\_SENSOR, CAL\_SENSOR, UUT\_SENSOR, and CAL\_ADPT per the "Configuration Diagram" above.
- b. Set the SOURCE mode to CW
- c. Set the SOURCE power to Off
- d. Set the SOURCE power level to -120 dBm or lowest power
- e. Connect the REF\_SENSOR, CAL\_SENSOR and UUT\_SENSOR to PC via USB cables.
- f. Start an instance of the PM\_APP for REF\_SENSOR, CAL\_SENSOR and UUT\_SENSOR.
- g. Preset each PM\_APP.
- h. Setup the equipment as depicted in "Absolute Level Accuracy Setup" diagram below. It is recommended that the SPLITTER and CAL\_ADAPT components be of high quality. Do not connect CAL\_SENSOR or UUT\_SENSOR to CAL\_ADAPT at this time. The open end of CAL\_ADAPT is the measurement plane. Do not connect any additional adapters or cables to the measurement plane.



Absolute Level Accuracy Setup

- i. If UUT has a female connector you should have a CAL\_ADAPT with Type N male in the setup. If UUT has a male connector you should have a CAL\_ADAPT with a Type N female in the setup.
- j. Ensure CAL\_SENSOR and UUT have the same type connector and same sex connector.
- k. Ensure the open end of the CAL\_ADAPT can mate directly with the CAL\_SENSOR and UUT.
- l. Preset each PM\_APP
- m. Set the CAL\_SENSOR and UUT\_SENSOR PM\_APPS as shown below:
  - i. Mode = CW
  - ii. Averages = 500
  - iii. Freq = Same as Source Freq
  - iv. Units = dBm
- n. Set the REF\_SENSOR PM\_APP as shown below:
  - v. Mode = CW
  - vi. Averages = 500
  - vii. Freq = Same as Source Freq
  - viii. Units = dB (relative dB)
- o. Repeat the steps in 4.o for each frequency listed in step 4.n of the TR.
  - ix. Carefully connect CAL\_SENSOR to measurement plane (open end of ATTEN\_20)
  - x. Set SOURCE frequency to first or next frequency in step 4.n of the TR and record it on the Worksheet
  - xi. Set the all PM\_APP frequencies to match SOURCE frequency
  - xii. Set SOURCE power On

- xiii. Set SOURCE power level so the CAL\_SENSOR PM\_APP reads within 0.100 dB of IDEAL\_CAL\_LEVEL indicated in step 4.n.xv of the TR
- xiv. *Record CAL\_SENSOR PM\_APP reading (Worksheet)*
- xv. Click the “Set Ref” button on REF\_SENSOR PM\_APP
- xvi. Carefully disconnect CAL\_SENSOR from measurement plane.
- xvii. Carefully connect UUT\_SENSOR to measurement plane.
- xviii. *Record the UUT PM\_APP reading (Worksheet)*
- xix. *Record the REF\_SENSOR PM\_APP reading (be certain to record the sign of this measurement)(Worksheet)*
- xx. Set SOURCE power off
- xxi. Carefully disconnect UUT from measurement plane.
- xxii. Calculate the LVL\_ERROR using the following equation and the results from steps 4.o.xiii, 4.o.xviii and 4.o.xix (Worksheet). Be careful not to drop the sign of the REF\_SENSOR measurement.


$$\mathbf{LVL\_ERROR\ (dB)\ =\ UUT\_SENSOR\ (dBm)\ -\ CAL\_SENSOR\ (dBm)\ -\ REF\_SENSOR\ (dB)}$$

- xxiii. Record the calculated LVL\_ERROR (Worksheet) onto the TR*
- xxiv. Repeat steps above until Level Accy TR is complete*
- n. Set the SOURCE power to Off
- o. Set the SOURCE power level to -120 dBm or lowest power
- p. Close all PM\_APPS
- q. Tear down “Absolute Level Accuracy Setup.”



## 5. Linearity

- a. Set the SOURCE mode to CW
- b. Set the SOURCE power to Off
- c. Set the SOURCE power level to -120 dBm or lowest power
- d. Connect the REF\_SENSOR and UUT to PC via USB cables.
- e. Start an instance of the PM\_APP for REF\_SENSOR, CAL\_SENSOR and UUT.
- f. Preset each PM\_APP.
- g. Setup the equipment as depicted in the “Linearity Setup” diagram below



Linearity Setup

- h. Set the REF\_SENSOR and UUT PM\_APPS as shown below:
  - i. Mode = CW
  - ii. Averages = 500
  - iii. Units = dBm
- i. Set SOURCE frequency equal to IDEAL\_SOURCE\_FREQ in TR
- j. Set SOURCE power On
- k. Set REF\_SENSOR and UUT\_SENSOR frequency to SOURCE frequency
- l. Set SOURCE level so that REF\_SENSOR PM\_APP indicates IDEAL\_LIN\_LEVEL specified in 5.v.v of TR +/- 0.100 dB
- m. Check UUT\_SENSOR PM\_APP power. UUT\_SENSOR PM\_APP should indicate within 3.00 dB of REF\_SENSOR PM\_APP.
- n. Change REF\_SENSOR PM\_APP measurement units to dB Relative
- o. Click REF\_SENSOR PM\_APP Set Ref button
- p. Change UUT\_SENSOR PM\_APP measurement units to dB Relative
- q. Click UUT PM\_APP Set Ref button

- r. Both PM\_APPS should indicate 0.000 dB +/- 0.050 dB and should be very stable.
  - s. *Note the REF\_SENSOR PM\_APP reading.*
  - t. *Note the UUT\_SENSOR PM\_APP reading.*
  - u. For the remainder of this test you will be asked to read the values indicated on the PM\_APPS as a result of changing SOURCE power level. Do not change any other settings on the PM\_APPS or SOURCE. Also, take great care not to physically disturb the setup.
  - v. Repeat the steps in 5.v for each level listed in step 5.v.v of the TR.
    - i. *Set SOURCE level to the first or next level in step 5.v of the TR and record on worksheet;*
    - ii. *Record REF\_SENSOR PM\_APP reading on worksheet (dB)*
    - iii. *Record UUT\_SENSOR PM\_APP reading on worksheet (dB)*
    - iv. Calculate the LIN\_ERROR using the following equation and the values from steps 5.v.ii, 5.v.iii and record on the worksheet. Be careful not to drop the sign of either reading.
- $$\text{LIN\_ERROR} = \text{REF\_SENSOR PM(dB)} - \text{UUT\_Sensor PM (dB)}$$
- v. *Record the calculated LIN\_ERROR on the worksheet and onto the TR*
  - vi. *Repeat above steps until TR Linearity is complete.*
  - w. *Set the SOURCE power to Off*
  - x. *Set the SOURCE power level to -120 dBm or lowest power*
  - y. *Close all PM\_APPS*
  - z. *Tear down the "Linearity Setup."*

**Linearity Worksheet**

<b><u>Power Level (dBm)</u></b>	<b><u>Ref SENSOR(dB) - UUT Sensor (dB)</u></b>	<b>=</b>	<b><u>LIN ERROR (dB)</u></b>
_____	_____ - _____	=	_____
_____	_____ - _____	=	_____
_____	_____ - _____	=	_____
_____	_____ - _____	=	_____
_____	_____ - _____	=	_____
_____	_____ - _____	=	_____

## Test Record for LB478A/ LB479A, Type N and Super SMA connectors

Model Number \_\_\_\_\_ SN \_\_\_\_\_ Date \_\_\_\_\_

Conn Type \_\_\_\_\_ Conn Sex \_\_\_\_\_ Temp \_\_\_\_\_ °C Humidity \_\_\_\_\_ %

Step	Measurement or Action	Measurement Range or Point	Lower Limit	Upper Limit	Measured Value	Result
2.a	UUT Physical Check	Inspection	-	-	-	Pass Fail
2.b	UUT Connector	Inspection				Pass Fail
2.j	Functional Test		-	-	-	Pass Fail
			-	-	-	
			-	-	-	
4.n.xv	Absolute Level Accuracy <b>IDEAL_CAL_LEVEL: -20 dBm</b>	10 MHz	-0.51 dB	+0.46 dB	____.____ dB	Pass Fail
		50 MHz	-0.51 dB	+0.46 dB	____.____ dB	Pass Fail
		100 MHz	-0.39 dB	+0.36 dB	____.____ dB	Pass Fail
		500 MHz	-0.39 dB	+0.36 dB	____.____ dB	Pass Fail
		1 GHz	-0.34 dB	+0.31 dB	____.____ dB	Pass Fail
		2 GHz	-0.30 dB	+0.28 dB	____.____ dB	Pass Fail
		3 GHz	-0.30 dB	+0.28 dB	____.____ dB	Pass Fail
		4 GHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		5 GHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
5.v.v	Linearity <b>IDEAL_SOURCE_FREQ: 1 GHz</b> <b>IDEAL_LIN_LEVEL: -25 dBm</b>	-25 dBm	-0.22 dB	+0.21 dB	____.____ dB	Pass Fail
		-20 dBm	-0.22 dB	+0.21 dB	____.____ dB	Pass Fail
		-15 dBm	-0.25 dB	+0.23 dB	____.____ dB	Pass Fail
		-10 dBm	-0.25 dB	+0.23 dB	____.____ dB	Pass Fail
		-5 dBm	-0.25 dB	+0.23 dB	____.____ dB	Pass Fail
		0 dBm	-0.25 dB	+0.23 dB	____.____ dB	Pass Fail

## Test Record for LB480A, Type N and Super SMA connectors

Model Number \_\_\_\_\_ SN \_\_\_\_\_ Date \_\_\_\_\_

Conn Type \_\_\_\_\_ Conn Sex \_\_\_\_\_ Temp \_\_\_\_\_ °C Humidity \_\_\_\_\_ %

Step	Measurement or Action	Measurement Range or Point	Lower Limit	Upper Limit	Measured Value	Result
2.a	UUT Physical Check	Inspection	-	-	-	Pass Fail
2.b	UUT Connector	Inspection				Pass Fail
2.j	Functional Test		-	-	-	Pass Fail
			-	-	-	
			-	-	-	
4.n.xv	Absolute Level Accuracy <b>IDEAL_CAL_LEVEL: -20 dBm</b>	50 MHz <sup>1</sup>	-0.51 dB	+0.46 dB	____.____ dB	Pass Fail
		100 MHz	-0.39 dB	+0.36 dB	____.____ dB	Pass Fail
		500 MHz	-0.39 dB	+0.36 dB	____.____ dB	Pass Fail
		1 GHz	-0.34 dB	+0.31 dB	____.____ dB	Pass Fail
		2 GHz	-0.30 dB	+0.28 dB	____.____ dB	Pass Fail
		3 GHz	-0.30 dB	+0.28 dB	____.____ dB	Pass Fail
		4 GHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		5 GHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		6 GHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
5.v.v	Linearity <b>IDEAL_SOURCE_FREQ: 1 GHz</b> <b>IDEAL_LIN_LEVEL: -25 dBm</b>	-25 dBm	-0.22 dB	+0.21 dB	____.____ dB	Pass Fail
		-20 dBm	-0.22 dB	+0.21 dB	____.____ dB	Pass Fail
		-15 dBm	-0.25 dB	+0.23 dB	____.____ dB	Pass Fail
		-10 dBm	-0.25 dB	+0.23 dB	____.____ dB	Pass Fail
		-5 dBm	-0.25 dB	+0.23 dB	____.____ dB	Pass Fail
		0 dBm	-0.25 dB	+0.23 dB	____.____ dB	Pass Fail

1. The 50 MHz calibration frequency is valid only for LB480A's that have a serial number that is > or equal to 117xxx (the xxx can be numbers and/or letters). For units that have a serial number < 117xxx, the minimum frequency to be tested is 100 MHz.



**Test Record for LB559A, Type N and Super SMA connectors**

Model Number \_\_\_\_\_ SN \_\_\_\_\_ Date \_\_\_\_\_

Conn Type \_\_\_\_\_ Conn Sex \_\_\_\_\_ Temp \_\_\_\_\_ °C Humidity \_\_\_\_\_ %

Step	Measurement or Action	Measurement Range or Point	Lower Limit	Upper Limit	Measured Value	Result
2.a	UUT Physical Check	Inspection	-	-	-	Pass Fail
2.b	UUT Connector	Inspection				Pass Fail
2.j	Functional Test		-	-	-	Pass Fail
			-	-	-	
			-	-	-	
4.n.xv	Absolute Level Accuracy <b>IDEAL_CAL_LEVEL: -20 dBm</b>	10 MHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		50 MHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		100 MHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		500 MHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		1 GHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		2 GHz	-0.30 dB	+0.28 dB	____.____ dB	Pass Fail
		3 GHz	-0.30 dB	+0.28 dB	____.____ dB	Pass Fail
		4 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		5 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		6 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		7 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		8 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		9 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		12.5 GHz	-0.35 dB	+0.33 dB	____.____ dB	Pass Fail
5.v.v	Linearity <b>IDEAL_SOURCE_FREQ: 1 GHz</b> <b>IDEAL_LIN_LEVEL: -25 dBm</b>	-25 dBm	-0.18 dB	+0.17 dB	____.____ dB	Pass Fail
		-20 dBm	-0.18 dB	+0.17 dB	____.____ dB	Pass Fail
		-15 dBm	-0.22 dB	+0.21 dB	____.____ dB	Pass Fail
		-10 dBm	-0.22 dB	+0.21 dB	____.____ dB	Pass Fail
		-5 dBm	-0.22 dB	+0.21 dB	____.____ dB	Pass Fail
		0 dBm	-0.22 dB	+0.21 dB	____.____ dB	Pass Fail

### Test Record for LB579A, Type N and Super SMA connectors

Model Number \_\_\_\_\_ SN \_\_\_\_\_ Date \_\_\_\_\_

Conn Type \_\_\_\_\_ Conn Sex \_\_\_\_\_ Temp \_\_\_\_\_ °C Humidity \_\_\_\_\_ %

Step	Measurement or Action	Measurement Range or Point	Lower Limit	Upper Limit	Measured Value	Result
2.a	UUT Physical Check	Inspection	-	-	-	Pass Fail
2.b	UUT Connector	Inspection				Pass Fail
2.j	Functional Test		-	-	-	Pass Fail
			-	-	-	
4.f			-			
4.n.xv	Absolute Level Accuracy <b>IDEAL_CAL_LEVEL: -20 dBm</b>	10 MHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		50 MHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		100 MHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		500 MHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		1 GHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		2 GHz	-0.30 dB	+0.28 dB	____.____ dB	Pass Fail
		3 GHz	-0.30 dB	+0.28 dB	____.____ dB	Pass Fail
		4 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		5 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		6 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		7 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		8 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		9 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		13 GHz	-0.40 dB	+0.37 dB	____.____ dB	Pass Fail
		14 GHz	-0.40 dB	+0.37 dB	____.____ dB	Pass Fail
15 GHz	-0.40 dB	+0.37 dB	____.____ dB	Pass Fail		
16 GHz	-0.40 dB	+0.37 dB	____.____ dB	Pass Fail		
17 GHz	-0.40 dB	+0.37 dB	____.____ dB	Pass Fail		
18 GHz	-0.40 dB	+0.37 dB	____.____ dB	Pass Fail		
5.v.v	Linearity <b>IDEAL_SOURCE_FREQ: 1 GHz</b> <b>IDEAL_LIN_LEVEL: -25 dBm</b>	-25 dBm	-0.18 dB	+0.17 dB	____.____ dB	Pass Fail
		-20 dBm	-0.18 dB	+0.17 dB	____.____ dB	Pass Fail
		-15 dBm	-0.22 dB	+0.21 dB	____.____ dB	Pass Fail
		-10 dBm	-0.22 dB	+0.21 dB	____.____ dB	Pass Fail
		-5 dBm	-0.22 dB	+0.21 dB	____.____ dB	Pass Fail
		0 dBm	-0.22 dB	+0.21 dB	____.____ dB	Pass Fail

### Test Record for LB589A, Super SMA Connectors

Model Number \_\_\_\_\_ SN \_\_\_\_\_ Date \_\_\_\_\_

Conn Type \_Super SMA\_\_\_\_\_ Conn Sex \_\_\_\_\_ Temp \_\_\_\_\_ °C Humidity \_\_\_\_\_ %

Step	Measurement or Action	Measurement Range or Point	Lower Limit	Upper Limit	Measured Value	Result
2.a	UUT Physical Check	Inspection	-	-	-	Pass Fail
2.b	UUT Connector	Inspection				Pass Fail
2.j	Functional Test		-	-	-	Pass Fail
			-	-	-	
			-	-	-	
4.n.xv	Absolute Level Accuracy <b>IDEAL_CAL_LEVEL: -20 dBm</b>	10 MHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		50 MHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		100 MHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		500 MHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		1 GHz	-0.31 dB	+0.29 dB	____.____ dB	Pass Fail
		2 GHz	-0.30 dB	+0.28 dB	____.____ dB	Pass Fail
		3 GHz	-0.30 dB	+0.28 dB	____.____ dB	Pass Fail
		4 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		5 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		6 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		7 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		8 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		9 GHz	-0.32 dB	+0.30 dB	____.____ dB	Pass Fail
		13 GHz	-0.40 dB	+0.37 dB	____.____ dB	Pass Fail
		14 GHz	-0.40 dB	+0.37 dB	____.____ dB	Pass Fail
		15 GHz	-0.40 dB	+0.37 dB	____.____ dB	Pass Fail
		16 GHz	-0.40 dB	+0.37 dB	____.____ dB	Pass Fail
		17 GHz	-0.40 dB	+0.37 dB	____.____ dB	Pass Fail
		18 GHz	-0.40 dB	+0.37 dB	____.____ dB	Pass Fail
		19 GHz	-0.46 dB	+0.42 dB	____.____ dB	Pass Fail
		20 GHz	-0.46 dB	+0.42 dB	____.____ dB	Pass Fail
21 GHz	-0.46 dB	+0.42 dB	____.____ dB	Pass Fail		
22 GHz	-0.46 dB	+0.42 dB	____.____ dB	Pass Fail		
23 GHz	-0.46 dB	+0.42 dB	____.____ dB	Pass Fail		
24 GHz	-0.46 dB	+0.42 dB	____.____ dB	Pass Fail		
25 GHz	-0.46 dB	+0.42 dB	____.____ dB	Pass Fail		
26 GHz	-0.46 dB	+0.42 dB	____.____ dB	Pass Fail		
26.5 GHz	-0.46 dB	+0.42 dB	____.____ dB	Pass Fail		
5.v.v	Linearity <b>IDEAL_SOURCE_FREQ: 1 GHz</b> <b>IDEAL_LIN_LEVEL: -25 dBm</b>	-25 dBm	-0.18 dB	+0.17 dB	____.____ dB	Pass Fail
		-20 dBm	-0.18 dB	+0.17 dB	____.____ dB	Pass Fail
		-15 dBm	-0.22 dB	+0.21 dB	____.____ dB	Pass Fail
		-10 dBm	-0.22 dB	+0.21 dB	____.____ dB	Pass Fail
		-5 dBm	-0.22 dB	+0.21 dB	____.____ dB	Pass Fail
		0 dBm	-0.22 dB	+0.21 dB	____.____ dB	Pass Fail

### Test Record for LB679A/ LB680A, Type N Connectors

Model Number \_\_\_\_\_ SN \_\_\_\_\_ Date \_\_\_\_\_

Conn Type \_N\_\_\_\_\_ Conn Sex \_\_\_\_\_ Temp \_\_\_\_\_ °C Humidity \_\_\_\_\_ %

Step	Measurement or Action	Measurement Range or Point	Lower Limit	Upper Limit	Measured Value	Result
2.a	UUT Physical Check	Inspection	-	-	-	Pass Fail
2.b	UUT Connector	Inspection				Pass Fail
2.j	Functional Test		-	-	-	Pass Fail
			-	-	-	
			-	-	-	
4.n.xv	Absolute Level Accuracy <b>IDEAL_CAL_LEVEL: -20 dBm</b>	50 MHz	-0.50 dB	+0.45 dB	____.____ dB	Pass Fail
		100 MHz	-0.44 dB	+0.40 dB	____.____ dB	Pass Fail
		500 MHz	-0.44 dB	+0.40 dB	____.____ dB	Pass Fail
		1 GHz	-0.38 dB	+0.35 dB	____.____ dB	Pass Fail
		2 GHz	-0.35 dB	+0.32 dB	____.____ dB	Pass Fail
		3 GHz	-0.35 dB	+0.32 dB	____.____ dB	Pass Fail
		4 GHz	-0.36 dB	+0.33 dB	____.____ dB	Pass Fail
		5 GHz	-0.36 dB	+0.33 dB	____.____ dB	Pass Fail
		6 GHz	-0.36 dB	+0.33 dB	____.____ dB	Pass Fail
		7 GHz	-0.36 dB	+0.33 dB	____.____ dB	Pass Fail
		8 GHz	-0.36 dB	+0.33 dB	____.____ dB	Pass Fail
		9 GHz	-0.36 dB	+0.33 dB	____.____ dB	Pass Fail
		10 GHz	-0.36 dB	+0.33 dB	____.____ dB	Pass Fail
		14 GHz	-0.44 dB	+0.40 dB	____.____ dB	Pass Fail
		15 GHz	-0.44 dB	+0.40 dB	____.____ dB	Pass Fail
16 GHz	-0.44 dB	+0.40 dB	____.____ dB	Pass Fail		
17 GHz	-0.44 dB	+0.40 dB	____.____ dB	Pass Fail		
18 GHz	-0.44 dB	+0.40 dB	____.____ dB	Pass Fail		
5.v.v	Linearity <b>IDEAL_SOURCE_FREQ: 1 GHz</b> <b>IDEAL_LIN_LEVEL: -0 dBm</b>	0 dBm	-0.25 dB	+0.23 dB	____.____ dB	Pass Fail
		-5 dBm	-0.25 dB	+0.23 dB	____.____ dB	Pass Fail
		-10 dBm	-0.25 dB	+0.23 dB	____.____ dB	Pass Fail
		-15 dBm	-0.25 dB	+0.23 dB	____.____ dB	Pass Fail
		-20 dBm	-0.30 dB	+0.28 dB	____.____ dB	Pass Fail
		-25 dBm	-0.38 dB	+0.35 dB	____.____ dB	Pass Fail

## Test Record for LB679A/ LB680A, Super SMA Connectors

Model Number \_\_\_\_\_ SN \_\_\_\_\_ Date \_\_\_\_\_

Conn Type    Super SMA    Conn Sex    Temp    °C Humidity    %

Step	Measurement or Action	Measurement Range or Point	Lower Limit	Upper Limit	Measured Value	Result
2.a	UUT Physical Check	Inspection	-	-	-	Pass Fail
2.b	UUT Connector	Inspection				Pass Fail
2.j	Functional Test		-	-	-	Pass Fail
			-	-	-	
			-	-	-	
4.n.xv	Absolute Level Accuracy <b>IDEAL_CAL_LEVEL: -20 dBm</b>	50 MHz	-0.50 dB	+0.45dB	____.____ dB	Pass Fail
		100 MHz	-0.44 dB	+0.40 dB	____.____ dB	Pass Fail
		500MHz	-0.44 dB	+0.40 dB	____.____ dB	Pass Fail
		1 GHz	-0.38 dB	+0.35 dB	____.____ dB	Pass Fail
		2 GHz	-0.35 dB	+0.32 dB	____.____ dB	Pass Fail
		3 GHz	-0.35 dB	+0.32 dB	____.____ dB	Pass Fail
		4 GHz	-0.36 dB	+0.33 dB	____.____ dB	Pass Fail
		5 GHz	-0.36dB	+0.33 dB	____.____ dB	Pass Fail
		6 GHz	-0.36dB	+0.33 dB	____.____ dB	Pass Fail
		7 GHz	-0.36dB	+0.33 dB	____.____ dB	Pass Fail
		8 GHz	-0.36dB	+0.33 dB	____.____ dB	Pass Fail
		9 GHz	-0.36dB	+0.33 dB	____.____ dB	Pass Fail
		10 GHz	-0.36dB	+0.33 dB	____.____ dB	Pass Fail
		14 GHz	-0.44 dB	+0.40 dB	____.____ dB	Pass Fail
		15 GHz	-0.44 dB	+0.40 dB	____.____ dB	Pass Fail
		16 GHz	-0.44 dB	+0.40 dB	____.____ dB	Pass Fail
		17 GHz	-0.44 dB	+0.40 dB	____.____ dB	Pass Fail
		18 GHz	-0.44 dB	+0.40 dB	____.____ dB	Pass Fail
		19 GHz	-0.47 dB	+0.43 dB	____.____ dB	Pass Fail
		20 GHz	-0.47 dB	+0.43 dB	____.____ dB	Pass Fail
5.v.v	Linearity <b>IDEAL_SOURCE_FREQ: 1 GHz</b> <b>IDEAL_LIN_LEVEL: -0 dBm</b>	0 dBm	-0.25 dB	+0.23 dB	____.____ dB	Pass Fail
		-5 dBm	-0.25 dB	+0.23 dB	____.____ dB	Pass Fail
		-10 dBm	-0.25 dB	+0.23 dB	____.____ dB	Pass Fail
		-15 dBm	-0.25 dB	+0.23 dB	____.____ dB	Pass Fail
		-20 dBm	-0.30 dB	+0.28 dB	____.____ dB	Pass Fail
		-25 dBm	-0.38 dB	+0.35 dB	____.____ dB	Pass Fail